## **EssentialLEDs**®


## WIRING SCHEMATICS FOR EssentialLEDs® PANEL (ELP-G)



**NON-DIM** (SHOWN IN SINGLE BRANCH CONFIGURATION)




**NON-DIM** (SHOWN IN MULTIPLE BRANCH CONFIGURATION)



## **DIMMABLE** with Class 2 Driver

## (SHOWN IN MULTIPLE BRANCH CONFIGURATION)



	Driver Size	Sq. Ft. of 1704
	40w	9.0
Class 2	48w	10.8
Drivers	72w	16.2
	96w	21.1

1. Figure for square feet of panel fixture per driver was calculated using a 90% load capacity for each wattage driver; drivers can be loaded higher - contact factory for advice. Some drivers require 50% minimum load for proper dimming. 2. Dimming performance will be impacted by type of driver, type of dimming, driver load and dimming control equipment; results will vary based on components used. 3. To determine correct wire gauge for your application, please refer to the voltage drop calculator on the VLT website (see Downloads tab in Drivers & Controls section). For constant voltage fixtures, VLT recommends a drop of no greater than one volt from driver to panel.

SYMBOLS WIRING

Line Voltage Input

Starter / Interconnect / Splitter

Essential LEDs® Light Panel

**VLT** 

page 141